Format is aligned with AusHFG RDS Requirement 1 noted in Summary Statement

EXAMPLE ROOM DATA SHEET

Standard Rooms

Building **HPU / Dept. Functional Unit Room Name**

SET of Rooms Standard

Room Func # **Room Number Room Code RLS Number** Toilet - Accessible

Z.1.075 WCAC From WCAC

DESIGN BRIEFING

Requirement 3 noted in **Summary Statement**

Briefed Area Hours of Operation 6.00 m² 24 Hours Designed Area 6.25 m^2 Ceiling Height

Occupancy

Remarks

Acoustics

Sound attenuation level high, Acoustic privacy is required.

Description / **Special** Requirements

A toilet and handbasin for use by disabled persons with or without assistance. The room shall comply with AS 1428. Baby change facilities may also be located in this room. The room may be used by patients or visitors. If the Accessible Toilet is located in a patient care area the patient/nurse call and emergency call points should be included. Additional design requirements: The entrance is to be flush with the adjoining floor. The door is to be fitted with escape hardware.

Room Note

SERVICES BRIEFING

AusHFG General Room Requirements

| Electrical | | |
|------------------------------------|-----|---------------------------|
| BODY PROTECTED | Yes | |
| Lighting | | |
| LIGHTING: fluorescent/LED, general | Yes | |
| HVAC | | |
| AIRCONDITIONING | Yes | EXHAUST: room exhaust Yes |
| Nurse Call | | |
| NURSE CALL SYSTEM | Yes | |

ITEM LISTS

Room Fabrics

Requirement 2 noted in **Summary Statement**

| Comment | Qty | Description | BIM ID | AusHFG# |
|--|-----|--|--------|----------|
| 201028 (-1) UG1 not required TK | 0 | CEILING: plasterboard, water resistant, drop-in tiles, prefinished, 600 x 1200 | CLG14 | CLTI-014 |
| | 1 | CORNICE: aluminium, 24mm shadow angle, powdercoat | COV02 | CLCN-002 |
| 201028 UG1 required TK | 1 | CEILING: plasterboard, flush set, suspended, paint, washable | CPB06 | CLFS-006 |
| Default = Vinyl coved; or tiles for tiled floor | 1 | SKIRTING: vinyl, floor vinyl coved, 150H, prefinished | SKI10 | FLSK-010 |
| Default = Vinyl; tiles also acceptable | 1 | FLOOR FINISH: vinyl, seamless, coved, standard slip resistant | VNS07 | FLVY-007 |
| | 1 | WALL FINISH: paint, acrylic, washable | WAL04 | WLWA-004 |
| 201028 (-1) UG1 not required TK Selection of material to comply with Part D Infection Prevention and Control AusHFG. | 0 | WALL FINISH: splashback | WAL07 | WLWA-007 |
| 201028 UG1 required TK | 1 | WALL FINISH: splashback, vinyl, to door height | WAL28 | WLWA-028 |

Doors

| | | | | 7. |
|--|-----|-----------------------|--------|----------|
| Comment | Qty | Description | BIM ID | AusHFG# |
| 210401 replaces DWSC-058 TK 201028 UG1 laminate required TK privacy latch, emergency release | 1 | none / to be selected | | AFDF-001 |
| 210401 replaces DWSC-058 TK 201028 UG1 laminate required TK privacy latch, emergency release | 1 | none / to be selected | | AFDL-001 |
| 210401 replaces DWSC-058 TK 201028 UG1 laminate required TK privacy latch, emergency release | 1 | none / to be selected | | DHAC-001 |

Page: 1 Printed: 14/05/2021

EXAMPLE ROOM DATA SHEET

Standard Rooms **RDS Rooms**

Room Func #

Building HPU / Dept. **Functional Unit Room Name**

SET of Rooms Standard

Room Number Room Code RLS Number Toilet - Accessible

Z.1.075 WCAC From WCAC

Doors

| AusHFG # | BIM ID | Description | Qty | Comment |
|----------|---------------|---|-----|---|
| DHDA-002 | | none / to be selected | Ĭ | 210401 replaces DWSC-058 TK 201028 UG1 laminate required TK privacy latch, emergency release |
| DHHW-001 | | none / to be selected | 1 | 210401 replaces DWSC-058 TK 201028 UG1 laminate required TK privacy latch, emergency release |
| DWSC-003 | | DOOR: 910mm c/o, single leaf, solid core, paint DO NOT USE | 0 | 201028 (-1) UG1 laminate required TK privacy latch, emergency release |
| DWSC-058 | | DOOR: 910mm c/o, single leaf, solid core, HP Laminate DO NOT USE | 0 | 210401 (-1) replaced with DISS-06 TK 201028 UG1 laminate required TK privacy latch, emergency release |
| DHFP-002 | DHFP02 | Door Frame Protection / Door Guards x4 (x2 both sides) / PVC / Adhesive Fixed / Custom Moulded for Frame / (Height TBC) | 1 | 210401 replaces DWSC-058 TK 201028 UG1 laminate required TK privacy latch, emergency release |
| DHLP-003 | DHLP03 | Door Leaf Protection / Kickplate (both sides / each leaf) / PVC / Adhesive Fixed / (Height TBC) | 1 | 210401 replaces DWSC-058 TK 201028 UG1 laminate required TK privacy latch, emergency release |
| DISS-006 | DISS06 | DOOR: 960 Single Leaf / Solid Core / Steel Framed / Laminate | 1 | 210401 replaces DWSC-058 TK 201028 UG1 laminate required TK privacy latch, emergency release |
| DWPR-006 | DO NOT USE | DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished DO NOT USE | 0 | 210426 (-1) replaced with Part/Sub in Door TK Both sides, equal to Acrovyn |
| DWPR-010 | DO NOT USE | DOOR PROTECTION: to door frame, PVC, prefinished (Height TBC) DO NOT USE | 0 | 210426 (-4) replaced with Part/Sub in Door TK 201028 UG1 increased from 1 to 4 TK 201022 PMO comment, required TK Optional. To be decided at project level. |
| DWPR-012 | DO NOT USE | DOOR PROTECTION: protection plate, to 800 AFFL, acrovyn, prefinished DO NOT USE | 0 | 201218 final coordination review TK 201028 UG1 required TK |

Packages

| AusHFG# | BIM ID | Description | Qty | Grp | Commen |
|----------|-----------|--|-----|-----|---|
| PKHB-018 | PKG-HB018 | PKG-HB018 Accessible Public Toilet WHB RH | 1 | | 210310 replaces individual items in FF&E Th |
| ELBO-020 | SWI008 | SWITCH: isolation | 1 | 1 | 210310 replaces individual items in FF&E T |
| FIBM-027 | MIR012 | MIRROR: fixed 450W X 1000H | 1 | 1 | 210310 replaces individual items in FF&E Tk |
| FIDI-025 | DIS011 | DISPENSER: paper/hand towel | 1 | 2 | 210310 replaces individual items in FF&E T |
| FIDI-030 | DIS013 | DISPENSER: soap | 1 | 2 | 210310 replaces individual items in FF&E TI |
| FIGE-018 | APL001 | PANEL: access, wall panel, stainless steel, 350 square | 1 | 1 | 210310 replaces individual items in FF&E T |
| FQCW-062 | BIN274 | BIN: waste, general, 20L, wall mounted | 1 | į | 210310 replaces individual items in FF&E T |
| HYBA-086 | BAS023 | BASIN: accessible with integrated shelf left hand side | 1 | î | 210310 replaces individual items in FF&E T |
| HYDR-017 | DRA100 | DRAIN: bottle trap | 1 | 1 | 210310 replaces individual items in FF&E T |
| HYGE-018 | VAL001 | VALVE: thermostatic, mixing | 1 | 1 | 210310 replaces individual items in FF&E TK |
| HYGE-029 | ACP001 | ACCESS PANEL: 400W x 400H | 1 | 1 | 210310 replaces individual items in FF&E T |
| HYTP-048 | TAP020 | TAPWARE: wall mounted spout with integrated | 1 | 1 | 210310 replaces individual items in FF&E Tk |
| | | sensor | | | |

Page: 2 Printed: 14/05/2021



Building HPU / Dept. **Functional Unit Room Name**

SET of Rooms Standard

Toilet - Accessible

Room Func # **Room Number Room Code RLS Number**

Z.1.075 WCAC From WCAC

Packages

| Comm | Grp | Qty | Description | BIM ID | AusHFG # |
|--|-----|-----|---|-----------|----------|
| 210310 replaces individual items in FF&E | | 1 | PKG-WC014 Accessible Public Toilet RH | PKG-WC014 | PKWC-014 |
| 210310 replaces individual items in FF&E | 1 | 1 | DISPENSER: toilet paper, large | DIS018 | FIDI-037 |
| 210310 replaces individual items in FF&E | 1 | 1 | TOILET SEAT: accessible, grey | TO/560 | FIGE-016 |
| 210310 replaces individual items in FF&E | 1 | 1 | GRAB RAIL: WC, 90 degree, 750x750mm | GRA005 | FIRT-006 |
| 210310 replaces individual items in FF&E | 1 | 1 | BACK REST: horizontal, patient, 400 x custom depth, to back of toilet TBC | BRA001 | FIRT-054 |
| 210310 replaces individual items in FF&E | 1 | 1 | GRAB RAIL: WC, hinged, LH bariatric, 850mm | GRA023 | FIRT-057 |
| 210310 replaces individual items in FF&E | 1 | 1 | VALVE: flushing, toilet | VAL120 | HYGE-026 |
| 210310 replaces individual items in FF&E | 1 | 1 | FLUSH BUTTON: toilet suite, accessible, with braille | FLU006 | HYTP-054 |
| 210310 replaces individual items in FF&E | 1 | 1 | TOILET SUITE: accessible, floor mounted | TO1003 | HYWC-001 |

Fittings, Furniture and Equipment (FF&E) Items

| Comme | Grp | Qty | Description | BIM ID | AusHFG # |
|---|-----|-----|---|--------|----------|
| 201014 must have shroud or insulated bottle trap waste UG1 TK 210216 Change to BAS009 as p CHC advisor accessibility review 1 | 1 | 0 | BASIN: handwash, accessible DO NOT USE | BAS004 | HYBA-005 |
| 210310 replaced by PKG-HB018 TK 2102 Change to BAS009 as per CHC advisor accessibil review 1 | 1 | 0 | BASIN: with integrated shelf DO NOT USE | BAS009 | HYBA-078 |
| 201028 (-1) UG1 wall mount required 7 | 3 | 0 | BIN: waste, general, 20L | BIN015 | FQCW-016 |
| 210509 PMO note required, not optional 7 Optional, depends on Waste Management Polic | 3 | 1 | BIN: waste, sanitary | BIN022 | FQCW-037 |
| 210216 Update nappy bin to wall mounted-20L-30 as per Accessibility Review 1 | | 1 | BIN: waste, nappy, 20L, wall mounted | BIN047 | FQCW-077 |
| 201103 bin added for nappy disposal TK 2102 Update nappy bin to wall mounted-20L-30L as p Accessibility Review 1 | 3 | 0 | BIN: waste, nappy, 50L | BIN153 | FQCW-066 |
| 210310 replaced by PKG-HB018 AM 201028 UC wall mount required 1 | :1 | 1 | BIN: waste, general, 20L, wall mounted | BIN274 | FQCW-062 |
| 210509 PMO note required, not optional option | -1 | 1 | CHANGE TABLE: baby, fold down, fixed on short side | CHG017 | FQBS-035 |
| 210310 replaced by PKG-HB018 T | 2 | 0 | DISPENSER: paper/hand towel | DIS011 | FIDI-025 |
| 210310 replaced by PKG-HB018 T K to handbas | 2 | 0 | DISPENSER: soap | DIS013 | FIDI-030 |
| 201214 (-1) Removed per UG2 comments receive | 1 | 0 | DISPENSER: toilet paper | DIS017 | FIDI-036 |
| 210310 replaced by PKG-WC014 TK 201214 | 1 | 0 | DISPENSER: toilet paper, large | DIS018 | FIDI-037 |
| 210209 added by PD UG - locate under toil grabrail 1 | 2 | 1 | DISPENSER: personal wipes, biodegradable, flushable | DIS873 | FIDI-056 |
| 210310 replaced by PKG-WC014 AM 2011 Added 1 | 1 | 1 | FLUSH BUTTON: toilet suite, patient | FLU001 | HYTP-002 |
| 201126 (-1) UG2 removed 1 | 1 | 0 | GRAB RAIL: WC, accessible use | GRA003 | FIRT-007 |

Page: 3 Printed: 14/05/2021



Building HPU / Dept. **Functional Unit Room Name**

SET of Rooms Standard

Toilet - Accessible

Room Func # **Room Number Room Code RLS Number**

Z.1.075 WCAC From WCAC

Fittings, Furniture and Equipment (FF&E) Items

| AusHFG# | BIM ID | Description | Qty | Grp | Comment |
|----------|--------|---|-----|-----|---|
| FIRT-006 | GRA005 | GRAB RAIL: WC, 90 degree, 750x750mm | 0 | 1 | 210310 replaced by PKG-WC014 TK |
| FIRT-008 | GRA009 | GRAB RAIL: WC, hinged, LH patient, 850mm DO NOT USE | 0 | 4 | 210310 replaced by PKG-WC014 TK 201215 rail required, added TK |
| FIRT-046 | GRA230 | GRAB RAIL: horizontal, to door 400mm | 1 | 1 | 201020 UG1 required for code TK |
| FIHR-026 | HOO006 | HOOK: coat, door mounted | 2 | 1 | 201014 Behind Door UG1 TK |
| FIBM-006 | MIR005 | MIRROR: fixed, glass (size tbc) | 0 | Ť | 201215 (-1) UG3 Removed in lieu of fixed size mirror TK |
| FIBM-027 | MIR012 | MIRROR: fixed 450W X 1000H | 0 | 1 | 210310 replaced by PKG-HB018 TK 201215 UG3 fixed size mirror requested TK |
| HYTP-035 | TAP010 | TAPWARE: mixer, basin, universal DO NOT USE | 0 | 1 | 210310 replaced by PKG-HB018 TK fixture mounted |
| HYWC-001 | TOI003 | TOILET SUITE: accessible, floor mounted | 0 | 1 | 210310 replaced by PKG-WC014 TK 201014 Must have concealed cistern or flushing valve. Must have Backrest UG1 TK With backrest. Concealed cistern, optional. |

Engineering Services

| Comment | Grp | Qty | Description | BIM ID | AusHFG# |
|---|-----|-----|--|--------|----------|
| 210509 PMO note required to IB only TK + indicator button & light, optional | 1 | 1 | BUTTON: nurse call, emergency | CAL003 | ITCL-004 |
| 210509 PMO note required to IB only TK + indicator button & light, optional | 1 | 1 | BUTTON: nurse call, patient to staff | CAL005 | ITCL-006 |
| 210509 PMO note required to IB only TK + indicated button & light, option | 1 | 1 | BUTTON: nurse call, staff assist | CAL006 | ITCL-008 |
| | 1 | 1 | DRAIN: floor waste | DRA002 | HYDR-004 |
| 210310 replaced by PKG-HB018 TK 201028 UG1 required to basin TK | 1 | 0 | DRAIN: bottle trap | DRA100 | HYDR-017 |
| 210209 added TK | 1 | 1 | SENSOR: motion detection, for lighting control, flush to ceiling | SEN003 | ITSE-045 |
| 210209 suggest removal for automatic control TK | 1 | 1 | SWITCH: light, single | SWI100 | ELBO-015 |

Page: 4 Printed: 14/05/2021